

<b>Extinguisher Type</b>	<b>Inspection</b>	<b>Maintenance</b>	<b>Recharging</b>	<b>Hydrostatic Testing</b>
Dry Chemical (Stored Pressure)	Dry Chemical (Stored)	1 Year	Empty and Internally Inspect @ 6 Years	12 Years
Dry Chemical (Stainless Steel)	30 Days	1 Year	5 Years	5 Years
Dry Chemical (Cartridge)	30 Days	1 Year	Empty and Internally Inspect @ 6 Years	12 Years
Carbon Dioxide	30 Days	1 Year	5 Years	5 Years
Water (Stored Pressure)	30 Days	1 Year	1 Year	5 Years
Wet Chemical	30 Days	1 Year	5 Years	5 Years
AFFF (Liquid Charge Type)	30 Days	1 Year	3 Years	5 Years
FFFP (Liquid Charge Type)	30 Days	1 Year	3 Years	5 Years
Dry Powder	30 Days	1 Year	Empty and Internally Inspect @ 6 Years	12 Years
Halogenated (Halon)	30 Days	1 Year	Empty and Internally Inspect @ 6 Years	12 Years